



- Backing to be 3/4" treated plywood
- Cabinet shall be 4'x4'x1' backing metal cabinet
- Terminal blocks shall have minimum 4 line side landings
- Terminal blocks shall accept no less than 500 MCM
- Salt River to provide meter base and CT's
- Salt River to lock cabinets and control access
- Cabinet and meter base to be installed and grounded by contractor
- Drawing can be rotated 180 degrees for OH service entrance